



COLORBOND PARAPET CAPPING WITH WEATHERING & PACKER TO SUIT. REFER TYPICAL PANEL REBATE DETAIL A ON THIS DRAWING.

150mm PRECAST CONCRETE TILT PANEL WALL & FIXINGS TO S.E. DETAIL TO OFFICE. PAINTED FINISH AS SPECIFIED EXTERNALLY.

PLEASE PROVIDE SHS TO SHS DIMENSION PFC & RAKER ANGLE RL

RAKING ANGLE WITH PURLIN CLEATS TO S.E. DETAIL FIXED TO PRECAST PANEL BEYOND.

COLORBOND FLASHINGS IN CAST-IN REGLET. (TYP.)

COLORBOND FLASHINGS AS SHOWN.

COLORBOND "LONGSPAN" ROOF SHEETING AT 1.5° PITCH OVER THERMAL BREAK AS SPECIFIED TO OFFICE IS THERE ON DRG A.06

140x45mm MGP10 TIMBER PURLINS WITH CLEATS TO PFC AND 75EA RAKING ANGLE AS SHOWN.

75x75mm SHS STEEL AWNING TRUSS TO S.E. DETAIL.

9mm VILLABOARD LINING WITH EXPRESSED JOINTS OVER STEEL TRUSS.

9mm VILLABOARD LINING OVER FURRING CHANNEL WITH 10mm EXPRESSED REBATE TO PERIMETER AS SHOWN. REFER ALSO TO OFFICE RCP.

ALUMINIUM FRAMED GLAZING AS SCHEDULED. (TYP.) SET FLUSH WITH OUTSIDE FACE OF PRECAST AND MASTIC SEAL TO FULL PERIMETER.

MODEL THE GUTTER

RAKING ANGLE WITH PURLIN CLEATS TO S.E. DETAIL.

WEBSIDE POP BOX GUTTER. 25mm OF GUTTER.

FURRING CHANNEL/TOP HATS USED TO FIX CLADDING OR BOARDS NORMALLY 40MM THICK

350W x 100mm DEEP ZINCALUME BOX GUTTER TO FALLS OVER MARINE PLY GUTTER BOARD. (TYP.)

KINGSPAN KOOLTHERM K12 30mm RIGID INSULATION TO ALL INTERNAL FACES OF PRECAST CONCRETE PANELS TO OFFICE & AMENITIES. (TYP.)

13mm PLASTERBOARD LINING FIXED ON 28mm FURRING CHANNELS @ 450 CTS OVER RIGID INSULATION AS DETAILED TO ALL INTERNAL FACES OF PRECAST CONCRETE PANELS TO OFFICE UNLESS OTHERWISE DETAILED. (TYP.)

350x350x100mm DEEP BOX GUTTER SUMP AND 80Ø RWP SHOWN DOTTED BEFORE.

ALUMINIUM FRAMED GLAZING AS SCHEDULED. (TYP.) SET FLUSH WITH OUTSIDE FACE OF PRECAST AND MASTIC SEAL TO FULL PERIMETER.

DETAIL 03. 1:10

ICCIIEN EAD BIIII NINIC DEDMIT